

14 February 2014

Mr. Jose Vilata Tamarit
Director Técnico
EDICOM
c/ Charles Robert Darwin, 8
Paterna, Valencia
Spain 46980

Re: Tier II Certification of Design Documents for the EDICOM – Edicom Business Center

Dear Mr. Jose Vilata Tamarit,


Uptime Institute is pleased to announce the Tier Certification of Design Documents for the EDICOM – Edicom Business Center, as fulfilling Tier II Redundant Components criteria. This Certification is based upon the design documentation submitted between 31 July 2013 and 10 February 2014.

This Certification recognizes the EDICOM – Edicom Business Center design as having redundant capacity components, as limited by the stated critical IT load of 133.2 kW.

Tier II Redundant Components criteria are founded on the idea of redundancy for critical capacity components which may allow for certain planned facility maintenance or modifications to redundant components. However, maintenance or modifications to mechanical or electrical distribution paths; equipment failures, or critical system faults within the critical components or distribution paths may lead to outages, both planned and unplanned. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

Sincerely,



Christopher Brown
Global Tier Authority